



2019/20 REPORT FOR TESTING LEAD CONTENT IN DRINKING WATER OF SCHOOL FACILITIES

School District Information		Health Authority (HA) Information	
SD No.	68	Region	
SD Name	Nanaimo-Ladysmith	Contact Name	
SD Contact Name:	Brian Hackwood	Contact Phone	
SD Contact Phone:	250 741 5258	Report Submitted to HA	
Report Date	Mar-20	Report Submission Date	

[Click here to access the School Master List for Facility Names and Facility Codes](#)

SCHOOL FACILITY INFORMATION	TEST INFORMATION	COMMUNICATION PLAN	ADDITIONAL INFORMATION
-----------------------------	------------------	--------------------	------------------------

School District Number	Ministry Facility Code	School Facility Name	Year Built	Date of Test (mm/yyyy)	Total Samples	Water Fixture Type	Room Location	Lead Level Result (mg/L)	Exceed Maximum Acceptable Concentrations	Mitigation Strategy Description	Describe Public Communication Plan	Comments	Next Scheduled Date of Testing (mm/yyyy)	Ministry Submission Period
68	6868018	Bayview Elementary School		07/2019	1	Sink	Room 103	0.001	No		Meeting with Principals to explain test results and remediation. Information sheets to be posted at each tested school. MOE and VIHA receiving all test results. Report to the Board together with Website information. 2 minute flush signage as required.	BV04-30s	Jan-21	30-Mar-20
68	6868018	Bayview Elementary School		07/2019	1	Sink	Room 107	0.000	No			BV05-30s		30-Mar-20
68	6868018	Bayview Elementary School		07/2019	1	Sink	Room 104	0.001	No			BV10-30s		30-Mar-20
68	6868018	Bayview Elementary School		07/2019	1	Sink	Room 102	0.001	No			BV11-30s		30-Mar-20
68	6868018	Bayview Elementary School		07/2019	1	Sink	Room 092	0.004	No			BV13-30s		30-Mar-20
68	6868019	Brechin Elementary School		06/2019	1	Sink	Girls Washroom Main Floor	0.001	No			BR03-30s		30-Mar-20
68	6868019	Brechin Elementary School		06/2019	1	Sink	Room 122	0.001	No			BR06-30s		30-Mar-20
68	6868019	Brechin Elementary School		06/2019	1	Sink	Medical Room	0.003	No			BR11-2min		30-Mar-20
68	6868009	Cedar Elementary School		06/2019	1	Water Fountain	Outside Room 111	0.001	No			CD01-0s	Jan-21	30-Mar-20
68	6868009	Cedar Elementary School		06/2019	1	Sink	Room 104	0.005	No			CD02-0s		30-Mar-20
68	6868009	Cedar Elementary School		06/2019	1	Sink	Room 110	0.007	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day. Add Auotflush and new faucet as required.	Meeting with Principals to explain test results and remediation. Information sheets to be posted at each tested school. MOE and VIHA receiving all test results. Report to the Board together with Website information. 2 minute flush signage as required.	CD03-0s		30-Mar-20
68	6868009	Cedar Elementary School		06/2019	1	Sink	Room 110	0.001	No			CD03-30s		30-Mar-20
68	6868009	Cedar Elementary School		06/2019	2	Sink	Room 105	0.009	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day. Add Auotflush and new faucet as required.		CD04-0s		30-Mar-20
68	6868009	Cedar Elementary School		06/2019	2	Sink	Room 105	0.001	No			CD04-30s		30-Mar-20
68	6868009	Cedar Elementary School		06/2019	2	Sink	Room 109	0.009	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day. Add Auotflush and new faucet as required.		CD05-0s		30-Mar-20
68	6868009	Cedar Elementary School		06/2019	2	Sink	Room 109	0.003	No			CD05-30s		30-Mar-20
68	6868009	Cedar Elementary School		06/2019	2	Sink	Room 106	0.008	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day. Add Auotflush and new faucet as required.		CD06-0s		30-Mar-20
68	6868009	Cedar Elementary School		06/2019	2	Sink	Room 106	0.001	No			CD06-30s		30-Mar-20
68	6868009	Cedar Elementary School		06/2019	2	Sink	Room 208	0.010	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day. Add Auotflush and new faucet as required.		CD07-0s		30-Mar-20
68	6868009	Cedar Elementary School		06/2019	2	Sink	Room 208	0.002	No			CD07-30s		30-Mar-20
68	6868009	Cedar Elementary School		06/2019	2	Sink	Room 202	0.006	Yes			CD08-0s		30-Mar-20
68	6868009	Cedar Elementary School		06/2019	2	Sink	Room 202	0.017	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day. Add Auotflush and new faucet as required.		CD08-30s		30-Mar-20
68	6868009	Cedar Elementary School		06/2019	2	Sink	Room 205	0.014	Yes			CD09-0s		30-Mar-20
68	6868009	Cedar Elementary School		06/2019	2	Sink	Room 205	0.003	No			CD09-30s		30-Mar-20
68	6868009	Cedar Elementary School		06/2019	2	Sink	Room 204	0.006	Yes			CD10-0s		30-Mar-20
68	6868009	Cedar Elementary School		06/2019	2	Sink	Room 204	0.012	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day. Add Auotflush and new faucet as required.		CD10-30s		30-Mar-20
68	6868009	Cedar Elementary School		06/2019	1	Water Fountain	Outside of Office	0.003	No			CD11-0s		30-Mar-20
68	6868009	Cedar Elementary School		06/2019	1	Water Fountain	Outside of Office	0.003	No			CD12-0s (DUP)		30-Mar-20
68	6868009	Cedar Elementary School		06/2019	2	Sink	First Aid Room	0.010	Yes			CD13-0s		30-Mar-20
68	6868009	Cedar Elementary School		06/2019	2	Sink	First Aid Room	0.007	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day. Add Auotflush and new faucet as required.		CD13-30s		30-Mar-20
68	6868009	Cedar Elementary School		06/2019	2	Sink	Kitchen	0.007	Yes			CD14-0s		30-Mar-20

SCHOOL FACILITY INFORMATION			TEST INFORMATION					COMMUNICATION PLAN	ADDITIONAL INFORMATION			
68	6868009	Cedar Elementary School	06/2019	2	Sink	Kitchen	0.002	No		CD14-30s	30-Mar-20	
68	6868009	Cedar Elementary School	06/2019	2	Sink	Gym Boys Changeroom	0.009	Yes		CD15-0s	30-Mar-20	
68	6868009	Cedar Elementary School	06/2019	2	Sink	Gym Boys Changeroom	0.011	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day. Add Auotflush and new faucet as required.	CD15-30s	30-Mar-20	
68	6868009	Cedar Elementary School	06/2019	2	Sink	Gym Girls Changeroom	0.011	Yes		CD16-0s	30-Mar-20	
68	6868009	Cedar Elementary School	06/2019	2	Sink	Gym Girls Changeroom	0.012	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day. Add Auotflush and new faucet as required.	CD16-30s	30-Mar-20	
68	6868009	Cedar Elementary School	06/2019	2	Water Fountain	Outside of Gym	0.010	Yes		CD17-0s	30-Mar-20	
68	6868009	Cedar Elementary School	06/2019	2	Water Fountain	Outside of Gym	0.004	No		CD17-30s	30-Mar-20	
68	6868009	Cedar Elementary School	06/2019	2	Sink	Staffroom	0.010	Yes		CD18-0s	30-Mar-20	
68	6868009	Cedar Elementary School	06/2019	2	Sink	Staffroom	0.002	No		CD18-30s	30-Mar-20	
68	6868009	Cedar Secondary School	06/2019	2	Sink	Storage Room	0.135	Yes		CS01-0s	30-Mar-20	
68	6868009	Cedar Secondary School	06/2019	2	Sink	Storage Room	0.027	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day. Add Auotflush and new faucet as required.	Meeting with Principals to explain test results and remediation. Information sheets to be posted at each tested school. MOE and VIHA receiving all test results. Report to the Board together with Website information. 2 minute flush signage as required.	CS01-30s	Jan-21 30-Mar-20
68	6868009	Cedar Secondary School	06/2019	2	Sink	Staff Mens Washroom	0.005	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day. Add Auotflush and new faucet as required.	CS02-0s	30-Mar-20	
68	6868009	Cedar Secondary School	06/2019	2	Sink	Staff Mens Washroom	0.002	No		CS02-30s	30-Mar-20	
68	6868009	Cedar Secondary School	06/2019	2	Sink	Staff Female Washroom	0.030	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day. Add Auotflush and new faucet as required.	CS03-0s	30-Mar-20	
68	6868009	Cedar Secondary School	06/2019	2	Sink	Staff Female Washroom	0.002	No		CS03-30s	30-Mar-20	
68	6868009	Cedar Secondary School	06/2019	2	Sink	Library Office	0.045	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day. Add Auotflush and new faucet as required.	CS04-0s	30-Mar-20	
68	6868009	Cedar Secondary School	06/2019	2	Sink	Library Office	0.004	No		CS04-30s	30-Mar-20	
68	6868009	Cedar Secondary School	06/2019	2	Sink	Washroom 409	0.008	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day. Add Auotflush and new faucet as required.	CS05-0s	30-Mar-20	
68	6868009	Cedar Secondary School	06/2019	2	Sink	Washroom 410	0.002	No		CS05-30s	30-Mar-20	
68	6868009	Cedar Secondary School	06/2019	2	Sink	Boys Washroom (by 409)	0.019	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day. Add Auotflush and new faucet as required.	CS06-0s	30-Mar-20	
68	6868009	Cedar Secondary School	06/2019	2	Sink	Boys Washroom (by 409)	0.003	No		CS06-30s	30-Mar-20	
68	6868009	Cedar Secondary School	06/2019	2	Sink	Main Office Medical Room	0.042	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day. Add Auotflush and new faucet as required.	CS07-0s	30-Mar-20	
68	6868009	Cedar Secondary School	06/2019	2	Sink	Main Office Medical Room	0.004	No		CS07-30s	30-Mar-20	
68	6868009	Cedar Secondary School	06/2019	2	Sink	Kitchen/Food/Textiles (closest to door)	0.012	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day. Add Auotflush and new faucet as required.	CS08-0s	30-Mar-20	
68	6868009	Cedar Secondary School	06/2019	2	Sink	Kitchen/Food/Textiles (closest to door)	0.003	No		CS08-30s	30-Mar-20	
68	6868009	Cedar Secondary School	06/2019	2	Sink	Construction Room	0.023	Yes		CS09-0s	30-Mar-20	
68	6868009	Cedar Secondary School	06/2019	2	Sink	Construction Room	0.013	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day. Add Auotflush and new faucet as required.	CS09-30s	30-Mar-20	
68	6868009	Cedar Secondary School	06/2019	2	Sink	Staffroom Kitchen	0.006	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day. Add Auotflush and new faucet as required.	CS10-0s	30-Mar-20	
68	6868009	Cedar Secondary School	06/2019	2	Sink	Staffroom Kitchen	0.004	No		CS10-30s	30-Mar-20	
68	6868009	Cedar Secondary School	06/2019	1	Sink	Staff Room Washroom	0.005	No		CS11-0s	30-Mar-20	
68	6868009	Cedar Secondary School	06/2019	1	Sink	Food room 107 (sink closest to door)	0.003	No		CS12-0s	30-Mar-20	
68	6868009	Cedar Secondary School	06/2019	1	Water Fountain	Outside of Gym Doors	0.002	No		CS13-0s	30-Mar-20	
68	6868009	Cedar Secondary School	06/2019	2	Sink	Gym Office Washroom (left most)	0.035	Yes		CS14-0s	30-Mar-20	
68	6868009	Cedar Secondary School	06/2019	2	Sink	Gym Office Washroom (left most)	0.012	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day. Add Auotflush and new faucet as required.	CS14-30s	30-Mar-20	
68	6868009	Cedar Secondary School	06/2019	2	Sink	Girls Changeroom	0.012	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day. Add Auotflush and new faucet as required.	CS15-0s	30-Mar-20	
68	6868009	Cedar Secondary School	06/2019	2	Sink	Girls Changeroom	0.005	No		CS15-30s	30-Mar-20	
68	6868009	Cedar Secondary School	06/2019	1	Sink	Boys Changeroom	0.002	No		CS16-0s	30-Mar-20	

SCHOOL FACILITY INFORMATION			TEST INFORMATION						COMMUNICATION PLAN	ADDITIONAL INFORMATION		
68	6868022	Chase River Elementary School	07/2019	1	Water Fountain	Outside of Copy Room	0.000	No	Meeting with Principals to explain test results and remediation. Information sheets to be posted at each tested school. MOE and VIHA receiving all test results. Report to the Board together with Website information. 2 minute flush signage as required.	CR02-2min	Jan-21	30-Mar-20
68	6868022	Chase River Elementary School	07/2019	1	Water Fountain	Outside of Copy Room	0.000	No		CR22-2min (DUP)		30-Mar-20
68	6868022	Chase River Elementary School	07/2019	1	Sink	Room 105	0.002	No		CR10-30s		30-Mar-20
68	6868022	Chase River Elementary School	07/2019	2	Sink	Room 114	0.006	Yes		CR11-30s		30-Mar-20
68	6868022	Chase River Elementary School	07/2019	2	Sink	Room 114	0.005	Yes	The drinking fountain should be replaced and/or an auto flushing valve be installed followed by subsequent retesting at 30-seconds and 2-minutes	CR11-2min		30-Mar-20
68	6868022	Chase River Elementary School	07/2019	1	Sink	Room 112	0.002	No		CR12-30s		30-Mar-20
68	6868022	Chase River Elementary School	07/2019	1	Sink	Room 110	0.002	No		CR13-30s		30-Mar-20
68	6868024	Cilaire Elementary School	06/2019	1	Sink	Boys Washroom Outside of Gym	0.004	No		CL03-30s		30-Mar-20
68	6868024	Cilaire Elementary School	06/2019	2	Sink	Medical Room	0.006	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day. Add Auotflush and new faucet as required.	CL06-30s		30-Mar-20
68	6868024	Cilaire Elementary School	06/2019	2	Sink	Medical Room	0.003	No		CL06-2min		30-Mar-20
68	6868024	Cilaire Elementary School	06/2019	1	Sink	Room A105	0.002	No		CL08-2min		30-Mar-20
68	6868024	Cilaire Elementary School	06/2019	1	Sink	Room A206	0.004	No		CL13-2min		30-Mar-20
68	6868024	Cilaire Elementary School	06/2019	1	Water Fountain	Outside of Room A205	0.003	No		CL14-2min		30-Mar-20
68	6868323	Cinnabar Elementary School	06/2019	1	Sink	Room 132	0.005	No	Meeting with Principals to explain test results and remediation. Information sheets to be posted at each tested school. MOE and VIHA receiving all test results. Report to the Board together with Website information. 2 minute flush signage as required.	CB01-0s	Jan-21	30-Mar-20
68	6868323	Cinnabar Elementary School	06/2019	2	Sink	Room 116	0.014	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day. Install new faucet.	CB02-0s		30-Mar-20
68	6868323	Cinnabar Elementary School	06/2019	2	Sink	Room 116	0.000	No		CB02-30s		30-Mar-20
68	6868323	Cinnabar Elementary School	06/2019	1	Water Fountain	Outside of Room 125	0.000	No		CB03-0s		30-Mar-20
68	6868323	Cinnabar Elementary School	06/2019	1	Sink	Multipurpose Room	0.001	No		CB04-0s		30-Mar-20
68	6868323	Cinnabar Elementary School	06/2019	2	Sink	Gym Boys Changeroom	0.005	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day. Install new faucet.	CB05-0s		30-Mar-20
68	6868323	Cinnabar Elementary School	06/2019	2	Sink	Gym Boys Changeroom	0.000	No		CB05-30s		30-Mar-20
68	6868323	Cinnabar Elementary School	06/2019	1	Sink	Girls Washroom 112	0.001	No		CB06-0s		30-Mar-20
68	6868323	Cinnabar Elementary School	06/2019	2	Sink	Office First Aid Room	0.037	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day. Install new faucet.	CB07-0s		30-Mar-20
68	6868323	Cinnabar Elementary School	06/2019	2	Sink	Office First Aid Room	0.002	No		CB07-30s		30-Mar-20
68	6868323	Cinnabar Elementary School	06/2019	1	Sink	Staff Room Washroom	0.000	No		CB08-0s		30-Mar-20
68	6868323	Cinnabar Elementary School	06/2019	2	Sink	Room 110	0.008	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day. Install new faucet.	CB09-0s		30-Mar-20
68	6868323	Cinnabar Elementary School	06/2019	2	Sink	Room 110	0.001	No		CB09-30s		30-Mar-20
68	6868323	Cinnabar Elementary School	06/2019	1	Water Fountain	Outside of Room 109	0.000	No		CB10-0s		30-Mar-20
68	6868323	Cinnabar Elementary School	06/2019	1	Sink	Room 133	0.003	No		CB11-0s		30-Mar-20
68	6868323	Cinnabar Elementary School	06/2019	1	Sink	Room 147	0.001	No		CB12-0s		30-Mar-20
68	6868323	Cinnabar Elementary School	06/2019	1	Sink	Room 135	0.001	No		CB13-0s		30-Mar-20
68	6868323	Cinnabar Elementary School	06/2019	1	Water Fountain	Outside of Room 141	0.000	No		CB14-0s		30-Mar-20
68	6868323	Cinnabar Elementary School	06/2019	1	Sink	Room 143	0.002	No		CB15-0s		30-Mar-20
68	6868323	Cinnabar Elementary School	06/2019	1	Sink	Room 143	0.002	No		CB16-0s (DUP)		30-Mar-20
68	6868323	Cinnabar Elementary School	06/2019	1	Sink	Portable 134	0.003	No		CB17-0s		30-Mar-20
68	6868323	Cinnabar Elementary School	06/2019	2	Sink	Portable 130	0.006	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day. Install new faucet.	CB18-0s		30-Mar-20
68	6868323	Cinnabar Elementary School	06/2019	2	Sink	Portable 131	0.001	No		CB18-30s		30-Mar-20

SCHOOL FACILITY INFORMATION			TEST INFORMATION						COMMUNICATION PLAN		ADDITIONAL INFORMATION		
68	6868325	Coal Tye Elementary School	06/2019	2	Sink	Room 108	0.011	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day. Install new faucet.	Meeting with Principals to explain test results and remediation. Information sheets to be posted at each tested school. MOE and VIHA receiving all test results. Report to the Board together with Website information. 2 minute flush signage as required.	CT01-0s	Jan-21	30-Mar-20
68	6868325	Coal Tye Elementary School	06/2019	2	Sink	Room 108	0.001	No			CT01-30s		30-Mar-20
68	6868325	Coal Tye Elementary School	06/2019	1	Water Fountain	Outside of Mechanical Room	0.000	No			CT02-0s		30-Mar-20
68	6868325	Coal Tye Elementary School	06/2019	1	Sink	Room 133	0.001	No			CT03-0s		30-Mar-20
68	6868325	Coal Tye Elementary School	06/2019	1	Sink	Room 102	0.001	No			CT04-0s		30-Mar-20
68	6868325	Coal Tye Elementary School	06/2019	1	Sink	Room 135	0.004	No			CT05-0s		30-Mar-20
68	6868325	Coal Tye Elementary School	06/2019	1	Sink	Room 131	0.001	No			CT06-0s		30-Mar-20
68	6868325	Coal Tye Elementary School	06/2019	1	Sink	Room 130	0.003	No			CT07-0s		30-Mar-20
68	6868325	Coal Tye Elementary School	06/2019	1	Water Fountain	Outside of Gym in access Corridor	0.001	No			CT08-0s		30-Mar-20
68	6868325	Coal Tye Elementary School	06/2019	1	Sink	Multipurpose Room (Right Most)	0.005	No			CT09-0s		30-Mar-20
68	6868325	Coal Tye Elementary School	06/2019	1	Sink	Multipurpose Room Kitchen	0.004	No			CT10-0s		30-Mar-20
68	6868325	Coal Tye Elementary School	06/2019	1	Sink	Staff Room 113	0.001	No			CT11-0s		30-Mar-20
68	6868325	Coal Tye Elementary School	06/2019	2	Sink	Library Office Room 127A	0.015	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day. Install new faucet.		CT12-0s		30-Mar-20
68	6868325	Coal Tye Elementary School	06/2019	2	Sink	Library Office Room 127A	0.001	No			CT12-30s		30-Mar-20
68	6868325	Coal Tye Elementary School	06/2019	1	Sink	Room 147	0.001	No			CT13-0s		30-Mar-20
68	6868325	Coal Tye Elementary School	06/2019	1	Sink	Room 122	0.002	No			CT14-0s		30-Mar-20
68	6868325	Coal Tye Elementary School	06/2019	1	Sink	Room 125	0.001	No			CT15-0s		30-Mar-20
68	6868028	Departure Bay Elementary	07/2019	2	Sink	Boys Washroom 130	0.010	Yes			DB02-0s		30-Mar-20
68	6868028	Departure Bay Elementary	07/2019	2	Sink	Boys Washroom 130	0.006	Yes	Maintain or add signage stating the water is not for human consumption at this location		DB02-30s		30-Mar-20
68	6868028	Departure Bay Elementary	07/2019	2	Sink	Medical Room in Office 111	0.012	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day		DB03-0s		30-Mar-20
68	6868028	Departure Bay Elementary	07/2019	2	Sink	Medical Room in Office 111	0.001	No			DB03-30s		30-Mar-20
68	6868028	Departure Bay Elementary	07/2019	2	Water Fountain	Outside of Boys Changeroom	0.005	No			DB13-0s		30-Mar-20
68	6868028	Departure Bay Elementary	11/2019	2	Water Fountain	Outside of Boys Changeroom	0.004	No			DB13-0s		30-Mar-20
68	6868028	Departure Bay Elementary	11/2019	2	Sink	Room 301	0.010	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day		DB15-0s		30-Mar-20
68	6868028	Departure Bay Elementary	11/2019	2	Sink	Room 301	0.002	No			DB15-30s		30-Mar-20
68	6868028	Departure Bay Elementary	07/2019	2	Sink	Staff Womens Washroom 310A Sink	0.025	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day		DB17-0s		30-Mar-20
68	6868028	Departure Bay Elementary	07/2019	2	Sink	Staff Womens Washroom 310A Sink	0.002	No			DB17-30s		30-Mar-20
68	6868028	Departure Bay Elementary	07/2019	2	Sink	Room 302	0.007	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day		DB21-0s		30-Mar-20
68	6868028	Departure Bay Elementary	07/2019	2	Sink	Room 302	0.004	No			DB21-30s		30-Mar-20
68	6868010	Dover Bay Secondary	06/2019	1	Water Fountain	Outside of Room 102	0.001	No			DB01-0s		30-Mar-20
68	6868010	Dover Bay Secondary	06/2019	1	Water Fountain	Outside of Room 103	0.001	No			DB02-0s (DUP)		30-Mar-20
68	6868010	Dover Bay Secondary	06/2019	2	Sink	Girls Washroom Nearby ELECT	0.005	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day. Install new faucet.	Meeting with Principals to explain test results and remediation. Information sheets to be posted at each tested school. MOE and VIHA receiving all test results. Report to the Board together with Website information. 2 minute flush signage as required.	DB03-0s	Jan-21	30-Mar-20
68	6868010	Dover Bay Secondary	06/2019	2	Sink	Girls Washroom Nearby ELECT	0.001	No			DB03-30s		30-Mar-20
68	6868010	Dover Bay Secondary	06/2019	1	Water Fountain	Outside of Girls Changeroom	0.003	No			DB04-0s		30-Mar-20
68	6868010	Dover Bay Secondary	06/2019	2	Sink	Office Washroom	0.019	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day. Install new faucet.		DB05-0s		30-Mar-20
68	6868010	Dover Bay Secondary	06/2019	2	Sink	Office Washroom	0.001	No			DB05-30s		30-Mar-20

SCHOOL FACILITY INFORMATION			TEST INFORMATION						COMMUNICATION PLAN		ADDITIONAL INFORMATION	
68	6868010	Dover Bay Secondary	06/2019	2	Sink	Boys Changeroom Left Most	0.021	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day. Install new faucet.	DB06-0s	30-Mar-20	
68	6868010	Dover Bay Secondary	06/2019	2	Sink	Boys Changeroom Left Most	0.001	No		DB06-30s	30-Mar-20	
68	6868010	Dover Bay Secondary	06/2019	1	Water Fountain	Outside of Boys Changeroom	0.004	No		DB07-0s	30-Mar-20	
68	6868010	Dover Bay Secondary	06/2019	1	Water Fountain	Outside of Room 202	0.003	No		DB08-0s	30-Mar-20	
68	6868010	Dover Bay Secondary	06/2019	1	Sink	Medical Room	0.001	No		DB09-0s	30-Mar-20	
68	6868010	Dover Bay Secondary	06/2019	1	Sink	Staff Room Kitchen	0.001	No		DB10-0s	30-Mar-20	
68	6868010	Dover Bay Secondary	06/2019	1	Sink	Library Seminar Room	0.002	No		DB11-0s	30-Mar-20	
68	6868010	Dover Bay Secondary	06/2019	1	Sink	Skills For Life Kitchen	0.001	No		DB12-0s	30-Mar-20	
68	6868010	Dover Bay Secondary	06/2019	1	Sink	Skills For Life Cleaning	0.004	No		DB13-0s	30-Mar-20	
68	6868010	Dover Bay Secondary	06/2019	1	Sink	Kitchen Room Centre Counter Far End	0.002	No		DB14-0s	30-Mar-20	
68	6868010	Dover Bay Secondary	06/2019	1	Sink	Foods Room Third From Door	0.001	No		DB15-0s	30-Mar-20	
68	6868010	Dover Bay Secondary	06/2019	2	Sink	Foods and Clothing Room 107 Closest to Door	0.002	No		DB16-0s	30-Mar-20	
68	6868010	Dover Bay Secondary	06/2019	2	Water Fountain	In Choral Room B109	0.006	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day. Install new faucet.	DB17-0s	30-Mar-20	
68	6868010	Dover Bay Secondary	06/2019	1	Water Fountain	In Choral Room B110	0.001	No		DB17-30s	30-Mar-20	
68	6868010	Dover Bay Secondary	06/2019	2	Water Fountain	In Instrumental Room B108	0.018	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day. Install new faucet.	DB18-0s	30-Mar-20	
68	6868010	Dover Bay Secondary	06/2019	2	Water Fountain	In Instrumental Room B109	0.004	No		DB18-30s	30-Mar-20	
68	6868010	Dover Bay Secondary	06/2019	2	Water Fountain	Outside of Medical Room	0.006	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day. Install new faucet.	DB19-0s	30-Mar-20	
68	6868010	Dover Bay Secondary	06/2019	2	Water Fountain	Outside of Medical Room	0.000	No		DB19-30s	30-Mar-20	
68	6868010	Dover Bay Secondary	06/2019	2	Sink	Science Lab Room Between Room D101 and D103 - Sink closest to D101	0.006	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day. Install new faucet.	DB20-0s	30-Mar-20	
68	6868010	Dover Bay Secondary	06/2019	2	Sink	Science Lab Room Between Room D101 and D103 - Sink closest to D101	0.000	No		DB20-30s	30-Mar-20	
68	6868010	Dover Bay Secondary	06/2019	2	Sink	Science Lab D102/D104 Backroom	0.013	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day. Install new faucet.	DB21-0s	30-Mar-20	
68	6868010	Dover Bay Secondary	06/2019	2	Sink	Science Lab D102/D104 Backroom	0.002	No		DB21-30s	30-Mar-20	
68	6868010	Dover Bay Secondary	06/2019	1	Sink	Science Lab D107 Main Desk Sink	0.004	No		DB22-0s	30-Mar-20	
68	6868010	Dover Bay Secondary	06/2019	1	Sink	Science Lab D109 Side Room Kitchen	0.005	No		DB23-0s	30-Mar-20	
68	6868010	Dover Bay Secondary	06/2019	1	Sink	Science Lab D109 Lab Sink 09	0.004	No		DB24-0s	30-Mar-20	
68	6868010	Dover Bay Secondary	06/2019	1	Water Fountain	Outside of Drafting Room C102	0.001	No		DB25-0s	30-Mar-20	
68	6868010	Dover Bay Secondary	06/2019	1	Sink	Kitchen Room C104A	0.001	No		DB26-0s	30-Mar-20	
68	6868010	Dover Bay Secondary	06/2019	1	Sink	Automotive Room C108 Right Most Sink	0.004	No		DB27-0s	30-Mar-20	
68	6868010	Dover Bay Secondary	06/2019	1	Sink	Construction Room C102 Left Most Sink	0.004	No		DB28-0s	30-Mar-20	
68	6868010	Dover Bay Secondary	06/2019	1	Sink	Teaching Kitchen Room C101 Sink	0.002	No		DB29-0s	30-Mar-20	
68	6868010	Dover Bay Secondary	06/2019	1	Water Fountain	Outside of Room 203	0.001	No		DB30-0s	30-Mar-20	
68	6868010	Dover Bay Secondary	06/2019	2	Sink	Boys Washroom Right Most Sink (2nd Floor)	0.012	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day. Install new faucet.	DB31-0s	30-Mar-20	
68	6868010	Dover Bay Secondary	06/2019	2	Sink	Boys Washroom Right Most Sink (2nd Floor)	0.001	No		DB31-30s	30-Mar-20	

SCHOOL FACILITY INFORMATION			TEST INFORMATION						COMMUNICATION PLAN		ADDITIONAL INFORMATION
68	6868030	Dufferin Crescent Elementary School	07/2019	2	Sink	Girls Washroom 130 Left Most Sink	0.007	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day	DC05-0s	30-Mar-20
68	6868030	Dufferin Crescent Elementary School	07/2019	2	Sink	Girls Washroom 130 Left Most Sink	0.002	No		DC05-30s	30-Mar-20
68	6868030	Dufferin Crescent Elementary School	07/2019	1	Sink	Washroom 132A	0.003	No		DC06-0s	30-Mar-20
68	6868030	Dufferin Crescent Elementary School	07/2019	2	Sink	Boys Washroom 131 Right Most Sink	0.009	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day	DC07-0s	30-Mar-20
68	6868030	Dufferin Crescent Elementary School	07/2019	2	Sink	Boys Washroom 131 Right Most Sink	0.004	No		DC07-30s	30-Mar-20
68	6868030	Dufferin Crescent Elementary School	07/2019	2	Sink	Girls Washroom 138 Right Most Sink	0.045	Yes		DC08-0s	30-Mar-20
68	6868030	Dufferin Crescent Elementary School	07/2019	2	Sink	Girls Washroom 138 Right Most Sink	0.010	Yes	Maintain or add signage stating the water is not for human consumption at this location	DC08-30s	30-Mar-20
68	6868030	Dufferin Crescent Elementary School	07/2019	1	Sink	Girls Changeroom 107	0.004	No		DC14-0s	30-Mar-20
68	6868030	Dufferin Crescent Elementary School	07/2019	1	Sink	Boys Washroom 110	0.001	No		DC15-0s	30-Mar-20
68	6868030	Dufferin Crescent Elementary School	07/2019	2	Sink	Room 208	0.009	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day	DC19-0s	30-Mar-20
68	6868030	Dufferin Crescent Elementary School	07/2019	2	Sink	Room 208	0.002	No		DC19-30s	30-Mar-20
68	6868030	Dufferin Crescent Elementary School	07/2019	1	Sink	Room 208	0.007	Yes		DC29-0s (DUP)	30-Mar-20
68	6868036	Fairview Community School	06/2019	1	Sink	Room 146	0.004	No		FCS10-30s	30-Mar-20
68	6868036	Fairview Community School	06/2019	2	Sink	Gym Kitchen	0.009	Yes		FCS14-2min	30-Mar-20
68	6868036	Fairview Community School	06/2019	2	Sink	Gym Kitchen	0.007	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day	FCS14-5min	30-Mar-20
68	6868036	Fairview Community School	06/2019	1	Sink	Room 105	0.005	No		FCS18-2min	30-Mar-20
68	6868036	Fairview Community School	06/2019	2	Sink	Room 103	0.020	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day	FCS22-2min	30-Mar-20
68	6868036	Fairview Community School	06/2019	2	Sink	Room 103	0.003	No		FCS22-5min	30-Mar-20
68	6868036	Fairview Community School	06/2019	2	Sink	Room 207	0.007	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day	FCS28-2min	30-Mar-20
68	6868036	Fairview Community School	06/2019	2	Sink	Room 207	0.006	Yes		FCS28-5min	30-Mar-20
68	6868037	Forest Park Elementary School	07/2019	4	Sink	Room B104	0.024	Yes		FP01-0s	30-Mar-20
68	6868037	Forest Park Elementary School	11/2019	4	Sink	Room B104	0.006	Yes		FP01-0s	30-Mar-20
68	6868037	Forest Park Elementary School	07/2019	4	Sink	Room B104	0.073	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day	FP01-30s	30-Mar-20
68	6868037	Forest Park Elementary School	11/2019	4	Sink	Room B104	0.003	No		FP01-30s	30-Mar-20
68	6868037	Forest Park Elementary School	07/2019	2	Sink	WCB by B103 Left Most Sink	0.072	Yes		FP02-0s	30-Mar-20
68	6868037	Forest Park Elementary School	07/2019	2	Sink	WCB by B103 Left Most Sink	0.019	Yes	Maintain or add signage stating the water is not for human consumption at this location	FP02-30s	30-Mar-20
68	6868037	Forest Park Elementary School	07/2019	2	Sink	WCG at Gym	0.010	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day	FP06-0s	30-Mar-20
68	6868037	Forest Park Elementary School	07/2019	2	Sink	WCG at Gym	0.002	No		FP06-30s	30-Mar-20
68	6868037	Forest Park Elementary School	07/2019	3	Sink	Kitchen at Gym	0.004	No		FP07-0s	30-Mar-20
68	6868037	Forest Park Elementary School	11/2019	3	Sink	Kitchen at Gym	0.030	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day	FP07-0s	30-Mar-20
68	6868037	Forest Park Elementary School	11/2019	3	Sink	Kitchen at Gym	0.002	No		FP07-30s	30-Mar-20
68	6868037	Forest Park Elementary School	11/2019	2	Sink	Kitchen at Gym	0.032	Yes		FPQ1-0s (DUP)	30-Mar-20
68	6868037	Forest Park Elementary School	11/2019	2	Sink	Kitchen at Gym	0.002	No		FPQ1-30s (DUP)	30-Mar-20
68	6868037	Forest Park Elementary School	07/2019	2	Sink	WCB at BA103	0.020	Yes		FP11-0s	30-Mar-20
68	6868037	Forest Park Elementary School	07/2019	2	Sink	WCB at BA103	0.007	Yes	Maintain or add signage stating the water is not for human consumption at this location	FP11-30s	30-Mar-20
68	6868038	Frank J. Ney Elementary	06/2019	1	Water Fountain	Outside of Storage Room By Gym	0.000	No		FN01-0s	30-Mar-20
68	6868038	Frank J. Ney Elementary	06/2019	1	Sink	Kitchen Room 109A	0.000	No		FN02-0s	30-Mar-20

SCHOOL FACILITY INFORMATION		TEST INFORMATION				COMMUNICATION PLAN		ADDITIONAL INFORMATION					
68	6868038	Frank J. Ney Elementary	06/2019	2	Sink	Medical Room by Office	0.006	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day. Add Auotflush and new faucet as required.	Meeting with Principals to explain test results and remediation. Information sheets to be posted at each tested school. MOE and VIHA receiving all test results. Report to the Board together with Website information. 2 minute flush signage as required.	FN03-0s	Jan-21	30-Mar-20
68	6868038	Frank J. Ney Elementary	06/2019	2	Sink	Medical Room by Office	0.001	No			FN03-30s		30-Mar-20
68	6868038	Frank J. Ney Elementary	06/2019	1	Sink	Staff Room	0.004	No			FN04-0s		30-Mar-20
68	6868038	Frank J. Ney Elementary	06/2019	1	Sink	Girls Change Room	0.004	No			FN05-0s		30-Mar-20
68	6868038	Frank J. Ney Elementary	06/2019	1	Sink	Library Office	0.005	No			FN06-0s		30-Mar-20
68	6868038	Frank J. Ney Elementary	06/2019	1	Sink	Kindergarten Room 204	0.003	No			FN07-0s		30-Mar-20
68	6868038	Frank J. Ney Elementary	06/2019	1	Sink	Kindergarten Room 203	0.001	No			FN08-0s		30-Mar-20
68	6868038	Frank J. Ney Elementary	06/2019	1	Sink	Room 111	0.002	No			FN09-0s		30-Mar-20
68	6868038	Frank J. Ney Elementary	06/2019	1	Sink	Room 122	0.001	No			FN10-0s		30-Mar-20
68	6868038	Frank J. Ney Elementary	06/2019	1	Sink	Room 115	0.002	No			FN11-0s		30-Mar-20
68	6868038	Frank J. Ney Elementary	06/2019	1	Water Fountain	Outside of Electrical Room 153	0.000	No			FN12-0s		30-Mar-20
68	6868038	Frank J. Ney Elementary	06/2019	1	Sink	Room 161	0.002	No			FN13-0s		30-Mar-20
68	6868038	Frank J. Ney Elementary	06/2019	1	Sink	Room 162	0.005	No			FN14-0s		30-Mar-20
68	6868038	Frank J. Ney Elementary	06/2019	1	Water Fountain	Outside of Room 254	0.000	No			FN15-0s		30-Mar-20
68	6868038	Frank J. Ney Elementary	06/2019	2	Sink	Room 254	0.008	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day. Add Auotflush and new faucet as required.		FN16-0s		30-Mar-20
68	6868038	Frank J. Ney Elementary	06/2019	2	Sink	Room 254	0.001	No			FN16-30s		30-Mar-20
68	6868038	Frank J. Ney Elementary	06/2019	1	Sink	Room 263	0.003	No			FN17-0s		30-Mar-20
68	6868038	Frank J. Ney Elementary	06/2019	2	Sink	Washroom by Room 257 Middle Sink	0.012	Yes			FN18-0s		30-Mar-20
68	6868038	Frank J. Ney Elementary	06/2019	2	Sink	Washroom by Room 257 Middle Sink	0.009	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day. Add Auotflush and new faucet as required.		FN18-30s		30-Mar-20
68	6868040	Gabriola Elementary School	06/2019	1	Sink	Med 100 B	0.001	No			GB01-30s		30-Mar-20
68	6868040	Gabriola Elementary School	06/2019	1	Sink	Room 110	0.001	No			GB05-30s		30-Mar-20
68	6868040	Gabriola Elementary School	06/2019	1	Sink	WCG 109	0.001	No			GB08-30s		30-Mar-20
68	6868040	Gabriola Elementary School	06/2019	1	Sink	Room 114	0.002	No			GB10-30s		30-Mar-20
68	6868040	Gabriola Elementary School	06/2019	1	Sink	Room 201	0.001	No			GB13-30s		30-Mar-20
68	6868040	Gabriola Elementary School	06/2019	1	Sink	WCG at Room 210	0.001	No			GB18-30s		30-Mar-20
68	6868040	Gabriola Elementary School	06/2019	1	Sink	Girls Shower 218D	0.001	No			GB24-30s (DUP)		30-Mar-20
68	6868041	Georgia Avenue Community School	07/2019	2	Sink	WCB Across From RM 19	0.005	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day		GA01-0s		30-Mar-20
68	6868041	Georgia Avenue Community School	07/2019	2	Sink	WCB Across From RM 20	0.001	No			GA01-30s		30-Mar-20
68	6868041	Georgia Avenue Community School	07/2019	2	Sink	Room 13	0.027	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day		GA07-0s		30-Mar-20
68	6868041	Georgia Avenue Community School	07/2019	2	Sink	Room 13	0.003	No			GA07-30s		30-Mar-20
68	6868041	Georgia Avenue Community School	07/2019	2	Sink	Room 01	0.018	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day		GA11-0s		30-Mar-20
68	6868041	Georgia Avenue Community School	07/2019	2	Sink	Room 01	0.002	No			GA11-30s		30-Mar-20
68	6868041	Georgia Avenue Community School	07/2019	1	Sink	WC Room 02	0.005	No			GA14-0s		30-Mar-20
68	6868041	Georgia Avenue Community School	07/2019	2	Sink	Room 08	0.020	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day		GA15-0s		30-Mar-20
68	6868041	Georgia Avenue Community School	07/2019	2	Sink	Room 08	0.002	No			GA15-30s		30-Mar-20
68	6868041	Georgia Avenue Community School	07/2019	2	Sink	Room 03	0.021	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day		GA19-0s		30-Mar-20
68	6868041	Georgia Avenue Community School	07/2019	2	Sink	Room 03	0.002	No			GA19-30s		30-Mar-20
68	6868041	Georgia Avenue Community School	07/2019	2	Sink	Room 02	0.023	Yes	Maintain or add signage for a 2 minute flush first use daily, run water until cold before drinking throughout the day		GA20-0s		30-Mar-20
68	6868041	Georgia Avenue Community School	07/2019	2	Sink	Room 02	0.004	No			GA20-30s		30-Mar-20
68	6868041	Georgia Avenue Community School	07/2019	2	Sink	WCB Across From Room 19	0.005	Yes			GA22 DUP-0s (DUP taken at GA07)		30-Mar-20
68	6868041	Georgia Avenue Community School	07/2019	2	Sink	WCB Across From Room 19	0.001	No			GA22 DUP-30s (DUP taken at GA01)		30-Mar-20

SCHOOL FACILITY INFORMATION	TEST INFORMATION	COMMUNICATION PLAN		ADDITIONAL INFORMATION
-----------------------------	------------------	--------------------	--	------------------------

68	6868044	Hammond Bay Elementary School	06/2019	1	Sink	Room 213	0.001	No	HB17-30s	30-Mar-20
----	---------	-------------------------------	---------	---	------	----------	-------	----	----------	-----------